



# **CITY OF WASHINGTON**

## **EMERGENCY WASTEWATER PLAN**

Adopted March 7, 2016  
Last Revision/Review  
February 7, 2022

<b>Chapter 1 .....</b>	<b>3</b>
<b>Purpose.....</b>	<b>3</b>
<b>Chapter 2 .....</b>	<b>3</b>
<b>Description.....</b>	<b>3</b>
<b>Chapter 3 .....</b>	<b>4</b>
<b>Disaster Organization.....</b>	<b>4</b>
3-1 <i>City Administrator– In-Charge Overall .....</i>	<i>4</i>
3-2 <i>Public Works Superintendent .....</i>	<i>4</i>
<b>Chapter 4 .....</b>	<b>4</b>
<b>Mutual Aid Agreement.....</b>	<b>4</b>
<b>Chapter 5 .....</b>	<b>4</b>
<b>Inventory of Emergency Equipment Available.....</b>	<b>4</b>
5-1 <i>City owned equipment:.....</i>	<i>4</i>
5-2 <i>Locally owned equipment and supplies:.....</i>	<i>5</i>
5-3 <i>Other Resources for Equipment:.....</i>	<i>5</i>
<b>Chapter 6 .....</b>	<b>5</b>
<b>Vulnerability of System (Disaster Response) .....</b>	<b>5</b>
6-1 <i>Accidental Spills or Contamination .....</i>	<i>5</i>
6-2 <i>City Buildings .....</i>	<i>6</i>
6-3 <i>Distribution System .....</i>	<i>6</i>
6-4 <i>Terrorist Threats .....</i>	<i>6</i>
<b>Chapter 7 .....</b>	<b>7</b>
<b>Emergency Contacts.....</b>	<b>7</b>
7-1 <i>City Contacts.....</i>	<i>7</i>
7-2 <i>Emergency Services (911).....</i>	<i>7</i>
7-3 <i>Federal and State Agencies .....</i>	<i>7</i>
7-4 <i>Services.....</i>	<i>7</i>
7-5 <i>Contractors.....</i>	<i>7</i>
7-6 <i>Media .....</i>	<i>8</i>
<b>Chapter 8 .....</b>	<b>9</b>
<b>Annual Review .....</b>	<b>9</b>

## **Chapter 1**

### **Purpose**

The City of Washington has compiled the following information and guidelines for the purpose of implementing an Emergency Wastewater Plan.

The purpose of this plan is to protect and treat wastewater during emergency conditions that will be used to protect human life and the environment in case of wastewater emergency.

## **Chapter 2**

### **Description**

The wastewater system for the City of Washington is a series of underground gravity piping to three lift stations which pump the sewage to the wastewater treatment ponds/lagoons. This system is permitted by Federal and Kansas Department of Health and Environment through their permitting process.

System Discharge Permit Numbers.

Kansas	M-BB21-0001
Federal	KS0089991

Location of Lagoons

SE1/4 NE ¼ SE ¼ Section 1 Township 3S Range 3E Washington County, Kansas

Boosters -- 3 Lift Stations

<b>Name</b>	<b>Address</b>
Main lift station	402 Airport Road, Washington, KS
Industrial park lift station	1647 Progress Street, Washington, KS
Park lift station	1012 D Street, Washington, KS

Population: 1087

Number of Service Connections: 619

How much: Design flow 0.18MGD

Storage: 19 Acres of Lagoons

Line Size: 8" to 12"

Other Connection: Irrigation of effluent

## **Chapter 3**

### **Disaster Organization**

#### **3-1 City Administrator– In-Charge Overall**

1. Coordinate and direct efforts of maintenance personnel and supplies in repair of damage or system failure.
2. Establish communications within the governing body; prepare information to be provided to the Public Information Officer (PIO) for release to local news media and general public.
3. Establish command posts, medical posts, shelters, etc. while working with Washington County Emergency Preparedness Personnel.

#### **3-2 Public Works Superintendent**

1. Assess damages and establish communication with the City Administrator.
2. Notify KDHE District Engineer or EPA and request assistance as needed.
3. Oversee any repairs or alterations from the collection, pumping and treatment throughout the wastewater system.
4. Request emergency equipment/supplies if needed.
5. Request work assistance if needed.
6. Contact power company (City of Washington) as to loss of power.
7. Connect and operate portable standby generator at main lift station if necessary.

## **Chapter 4**

### **Mutual Aid Agreement**

Cooperative arrangement for possible containment with Washington County Emergency Preparedness Personnel.

Cooperative arrangements for wastewater repair parts and fittings have been made with neighboring cities if needed.

## **Chapter 5**

### **Inventory of Emergency Equipment Available**

#### **5-1 City owned equipment:**

Mini excavator, 42 hp.

4-Wheel Loader, 2¼ yard bucket.

Dump truck, 5 yards.

Skid steer, 65 hp , ¾ yard bucket.

Gas monitor.

2 Generators - 2000 Onan (10kv,120/240) and 2009 Generac (60 kv, 120/240/480)

Trash pumps, 1 ½", 3".

Sewer cleaner jetter, 1300 psi, ¾" hose.

Sewer camera.

1-8" air plug.

1-12" air plug.

Shoring Trailer – 6-4'x8' shoring boards, ¾"; 1-4'x4' plywood, ¾"; 3-22"-36" shoring jacks, 18" long; 3-22"-36" shoring jacks, 5' long; hydraulic hand pump; 12-Altum mats 3'x8'; 1-50' extension cord; 2-jack lowering handles.

## **5-2 Locally owned equipment and supplies:**

1. City of Marysville, KS 785-562-5331  
Kent Bargman, Operator 785-562-7176  
*Jetter Vac Truck, Camera, Safety Equipment*
2. City of Hanover, Kansas 785-337-2242  
City Shop 785-337-2591  
Scott Wieden 402-223-9750  
*Pipe Poles, Grit Catcher, Tripod*
3. Rusty Johnson, Washington, KS 785-541-1085  
*Septic Truck*

## **5-3 Other Resources for Equipment:**

KDHE, KRWa and KMU may be called for any other equipment and tools needed. Examples of possible equipment and tools could be generators, portable pumps for bypass pumping, pipe and fittings and any other item that may help in an emergency. All agencies will do their best to help locate needed items as soon as possible.

# **Chapter 6**

## **Vulnerability of System (Disaster Response)**

### **6-1 Accidental Spills or Contamination**

In the case of an accidental spill or migration of damaging liquids such as petroleum products or cleaners or the like.

1. Operator shall contact 911.
2. Operator will assess the situation and notify KDHE, Regional EPA Office, or Office of Emergency Preparedness of extent of damage.
3. In the event of a bypass incident the Operator will notify the KDHE Central Office within 24 hours of discovery (email – [Chris.Seeds@ks.gov](mailto:Chris.Seeds@ks.gov)), (fax 785-559-4257), or the local KDHE district office Marsha Fleming (785-827-9639 or 785-201-4685).

4. If an incident is after hours and represents a significant public health threat call 785-296-1679 IMMEDIATELY!
5. Establish communications through the Washington County Sheriff's Office, Public Information Officer (PIO) and fire.
6. PIO shall prepare and distribute information to news media and general public as necessary.
7. Operator shall make sure that all sources of contaminated waste are secured and the discharge gates at the lagoons are closed and monitored to ensure contamination doesn't flow into discharge stream.
8. Upon direction of City Administrator, the City shall notify residents immediately to limit water usage until hazard has been mitigated.

## **6-2 City Buildings**

1. Power outage due to natural or man-made disaster.
  - a. The City will utilize a generator and restore electricity to wastewater lift stations.
  - b. The City will ascertain from Prairie Land Electric Cooperative when power will be restored and/or initiate city generation.
2. Excessive damage to Treatment Facilities and City Buildings
  - a. Operator will assess damages and report to the City Administrator.
  - b. City Administrator will establish communication with the Mayor and governing body, and prepare information to be provided to the PIO) for release to the news media and general public.
  - c. The City's ordinance will go into effect regulating the non-essential use of water during an emergency upon authorization from the Mayor.
  - d. Upon direction of City Administrator, the Operator will notify KDHE of any anticipated needs.
  - e. The City Administrator will authorize a work force to repair damages to bring system back on line.

## **6-3 Distribution System**

1. Collection Main Damage.
  - a. Isolate main and repair.
2. Wastewater Pond Damage/Contamination.
  - b. The City's Ordinance will go into effect regulating the non-essential use of water during an emergency upon authorization from the Administrator, if needed.
  - c. City shall take immediate action to address damage or make preparation in cooperation with the proper authorities for contamination removal.

## **6-4 Terrorist Threats**

Notify Operator, City Administrator, and Mayor of threat and coordinate with civil defense personnel to provide protection of Washington's wastewater treatment system

## Chapter 7 Emergency Contacts

### 7-1 City Contacts

Carl Chalfant	City Administrator	785-220-4175	24 Hour
Denise Powell	City Clerk (PIO)	785-747-8534	24 Hour
Christopher Milam	Public Works Supt.	785-747-6876	24 Hour

#### Operators:

Carl Chalfant	785-220-4175	24 Hour
Christopher Milam	785-747-6876	24 Hour
City Emergency Cell	785-541-1313	24 Hour

### 7-2 Emergency Services (911)

Washington County Sheriff	785-325-2293	24 Hour
Washington EMS	785-325-2293	24 Hour
Washington County Fire District	785-325-2293	24 Hour
Washington County Emergency Preparedness	785-325-2134	8-5, M-F
Randy Hubbard	785-541-0212	Cell 24 Hour
Washington County Health Department	785-325-2600	8am-5pm

### 7-3 Federal and State Agencies

Kansas Dept. of Health & Environment	North Central District Office, Salina	785-827-9639	8-5, M-F
On-Call Officer	Emergency Spill Line	785-291-3333	24 Hour
Kansas Adjutant General Department		785-646-1409	8-5, M-F
Environmental Protection Agency	Region 7, Kansas City, KS	913-281-0991	24 Hour

### 7-4 Services

Kansas One-Call Dig Safe		800-344-7233	24 Hour
Kansas Municipal Utilities, KSMAP		620-241-1423	8-5, M-F
	Brad Mears Emergency Contact	785-364-0670	24 Hour
Kansas Rural Water Association	Elmer Ronnebaum, General Manager	785-336-3760	8-5, M-F
	Ken Kopp	785-260-5381	After 5pm

### 7-5 Contractors

RJ Septic Service	Septic Truck	785-541-1085	24 Hour
-------------------	--------------	--------------	---------

Mayer Specialty Services, LLC	Sewer Cleaning & Inspection Equipment	316-794-1165	8-5, M-F
	Emergency Number	316-794-3780	24 Hour
Midlands Contracting, Inc.	Sewer Cleaning & Inspection Equipment	308-237-7979	8-5, M-F
Pace Analytical Services	Testing	785-827-1273	8-5, M-F
	Greg Groene, General Manager	785-826-0189	24 Hour
Haynes Equipment Company	Lift Station Equipment & Supplies	913-782-4962	8-5, M-F
	Parts & Service Number	913-782-5013	24 Hour
Utility Maintenance Contractors, LLC	Emergency Cleaning & Inspection Equipment	316-945-8833	8-5, M-F
	Greg Bruggeman, General Manager	316-993-8788	24 Hour
City of Marysville	Sewer Vac Truck	785-562-5331 785-562-7176	8-5, M-F After Hours
Chuck Walter	Backhoe, Skidloader	785-747-7147	24 Hour
Orville Jueneman Construction	Dump Truck, Track Hoe, Grader, Loader	785-337-2482	7-6, M-F

Engineer:

BG Consultants, Manhattan	785-537-7448	M-F, 8-5
CES Group, P.A.	785-562-5148	M-F, 8-5

Material Supplier:

The Salina Supply	800-288-1231
Core & Main	800-892-4304
Municipal Supply, Inc	402-462-4191

## 7-6 Media

KCLY Radio FM	785-632-5661, <a href="mailto:news@kclyradio.com">news@kclyradio.com</a> , Facebook
KNDY Radio FM 95.5, FM 94.1 & AM 1570	785-562-2361, <a href="mailto:kndy@bluevalley.net">kndy@bluevalley.net</a> , Facebook
Washington County News	785-325-2219, <a href="mailto:editor@bluevalley.net">editor@bluevalley.net</a> ,
KDHE – NC District	785-827-9639
City of Washington	785-325-2284, <a href="mailto:wsems@washingtontks.net">wsems@washingtontks.net</a> Facebook, city website at <a href="http://www.washingtontks.net">www.washingtontks.net</a>
IRIS Alert – Washington County Sheriff or Randy Hubbard, Emergency Preparedness Coordinator	785-325-2293 785-325-2134 (office) or 785-541-0212 (cell)



## Chapter 8 Annual Review

Annual Review Sign Off Sheet:

It shall be required that this policy be reviewed annually by the City of Washington City Council and their Operator.

Approved By:

Ryan W. Kern 2-7-2022  
Ryan W. Kern, Mayor Date

Carl D. Chalfant 2/7/2022  
Carl D. Chalfant, City Administrator Date

Chris Milam 2-7-2022  
Chris Milam, Public Works Superintendent Date